

# IAPMO R&T OCEANA

7-11 Fullard Road, Narre Warren, Victoria 3805, Australia



IAPMO R&T Oceana is a product certification body which inspects and arranges for the independent laboratory testing of samples taken from the manufacturer's stock or from the market or a combination of both, to verify compliance of the requirements of applicable Standards and Specifications. This activity is coupled with periodic surveillance of the manufacturer's factory and any major subcontractor's site/s as well as the assessment of the manufacturer's Quality Assurance System. This certification is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO R&T Oceana of the product acceptance by Authorities Having Jurisdiction.

## CERTIFICATE OF CONFORMITY

*IAPMO R&T Oceana hereby grants to:*

### **Aliaxis Nederland BV**

Industrieterrein 11, Panningen, NK 5981 Netherlands

*the right to use the WaterMark in accordance with the ABCB Manual for the WaterMark Certification Scheme;— Australian Standards; WaterMark Technical Specifications; and the Plumbing Code of Australia; only in respect of the certified product as described in the WaterMark Certificate of Conformity – Schedule of Certified Product (Refer also IAPMO Product Listing Directory). The Certificate is granted subject to the rules governing the WaterMark Certification Scheme and the Terms and Conditions of the Approved User Agreement and IAPMO Oceana's WaterMark Governance Rules.*

*Evaluated to:*

**AS/NZS 4936-2002**

**Air admittance valves (AAVs) for use in sanitary plumbing and drainage systems**

*Manufacturer:*

Refer to Licence Holder

**Licence No.:** WM-022830

**First Certified:** 31 July 2018

**Certification Date:** 31 July 2021

**Expiry Date:** 30 July 2026

  
CEO, The IAPMO Group

This WaterMark certification is for the period indicated herein and is void after the date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of IAPMO R&T Oceana, or any evidence of non-compliance with applicable Standards, Specifications or of inferior workmanship, may be deemed sufficient cause for revocation of this certification. Reproduction of or reference to this certificate for advertising purposes may be made only by specific written permission of IAPMO R&T Oceana. Any alteration of this certificate could be grounds for revocation of this certification.

"This certificate is issued by a JAS-ANZ accredited Conformity Assessment Body. The ABCB and JAS-ANZ do not in any way warrant, guarantee or represent that the product the subject of this Certificate conforms to the WaterMark Certification Scheme Rules, nor accepts any liability arising out of the use of the product. The ABCB disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Certificate."



# WATERMARK CERTIFICATE OF CONFORMITY

## SCHEDULE OF CERTIFIED PRODUCT



*Certificate Holder*

**Aliaxis Nederland BV**

A.B.N.:

Industrieterrein 11, Panningen, NK 5981 Netherlands

*Manufacturer*

**Refer to Licence Holder**

*Standard*

**AS/NZS 4936-2002**

**Air admittance valves (AAVs) for use in sanitary plumbing and drainage systems**

**Licence No. WM-022830**

**Certification Date: 31 July 2021**

**Expiry Date: 30 July 2026**

**First Certified: 31 July 2018**

Brand Name	Model Name	Model ID	Product Type	Product Description	End Connection	Rated Capacity	Flow Rate	Material
Studor	Mini-Vent	49017, 49018	Air admittance (induct/one way)	DN 32 Air Admittance Valve	Flexible push-fit	94 Fixture Units (Group)	7.5 L/s	ABS
Studor	Mini-Vent	49009, 49010, 49018	Air admittance (induct/one way)	DN 40 Air Admittance Valve	R1-1/2	94 Fixture Units (Group)	7.5 L/s	ABS
Studor	Mini-Vent	49017, 49018	Air admittance (induct/one way)	DN 50 Air Admittance Valve	Flexible push-fit	94 Fixture Units (Group)	7.5 L/s	ABS
Studor	Redi-Vent	49202	Air admittance (induct/one way)	DN 32 Air Admittance Valve	Flexible push-fit	10 Fixture Units (Group)	2.4 L/s	ABS
Studor	Redi-Vent	49202	Air admittance (induct/one way)	DN 40 Air Admittance Valve	R1-1/2	10 Fixture Units (Group)	2.4 L/s	ABS
Studor	Redi-Vent	49202	Air admittance (induct/one way)	DN 50 Air Admittance Valve	Flexible push-fit	10 Fixture Units (Group)	2.4 L/s	ABS
Studor	Maxi-Vent	49112	Air admittance (induct/one way)	DN 80 Air Admittance Valve	Flexible push-fit	1728 Fixture Units (Group) 125 Fixture Units (Stack)	32 L/s	ABS
Studor	Maxi-Vent	49112	Air admittance (induct/one way)	DN 100 Air Admittance Valve	Flexible push-fit	1728 Fixture Units (Group) 125 Fixture Units (Stack)	32 L/s	ABS
Studor	Tec-Vent	49209	Air admittance (induct/one way)	DN 40 Air Admittance Valve	R1-1/2	94 Fixture Units (Group)	7.5 L/s	Flame retardant polycarbonate (unverified)

**END RECORD**

**END RECORD**

CEO, The IAPMO Group